

652 Oliver Street Williamsport, PA. 17701 U.S.A.

Telephone +1 (800) 258-3279 U.S. and Canada (Toll Free)

Telephone +1 (570) 323-6181 (Direct)

Facsimile +1 (570) 327-7101

www.lycoming.com

SERVICE INSTRUCTION

DATE: May 13, 2016 Service Instruction No. 1255A

(Supersedes Service Instruction No. 1255)

Engineering Aspects are FAA (DER) Approved

SUBJECT: Thermostatic Oil Cooler Bypass Valve Replacement

MODELS AFFECTED: Lycoming engines using thermostatic oil cooler bypass valve

TIME OF COMPLIANCE: At 100-hour inspection or when high oil temperature is noted

REASON FOR REVISION: Updated bypass valve replacement part numbers; added respective detailed

bypass valve replacement instructions for engines with oil pressure screens

and oil filters

NOTICE: Incomplete review of all the information in this document can cause errors. Read the entire Service Instruction to make sure you have a complete understanding of the requirements.

This revision of the Service Instruction identifies thermostatic oil cooler bypass valve P/N 53E22144 (Figure 1) (or other superseding bypass valve identified in the latest revision of Service Instruction SI-1565) as a superseding replacement bypass valve for either bypass valve P/N LW-10269 or P/N 75944.

Lycoming Engines recommends using thermostatic oil cooler bypass valve P/N 53E22144, identified in the latest revision of Service Instruction No. SI-1565.




Figure 1
Thermostatic Oil Cooler Bypass Valves



ISSUED				REVIS	ED	PAGE NO.	REVISION
MO	DAY	YEAR	MO	DAY	YEAR	1 of 2	Δ.
08	04	72	05	13	16	1 01 2	Α

Thermostatic Oil Cooler Bypass Valve Replacement Instructions

On engines with an oil pressure screen (Figure 2):

- 1. Remove the oil cooler bypass valve and gasket from the oil pressure screen housing. Discard the gasket.
- 2. Apply Food Grade Anti-Seize on the threads of the thermostatic oil cooler bypass valve.
- 3. Install the thermostatic oil cooler bypass valve with a new gasket on the oil pressure screen housing (Figure 2).
- 4. Torque the thermostatic oil cooler bypass valve to 300 in.-lbs. (34 Nm).
- 5. Lockwire the thermostatic oil cooler bypass valve.




Figure 2
Oil Cooler Bypass Valve
(Engine with Oil Pressure Screen)

On engines with an oil filter (Figure 3):

- 1. Remove the oil cooler bypass valve from the oil filter base. Discard the gasket.
- 2. Apply Food Grade Anti-Seize on the threads of the thermostatic oil cooler bypass valve
- 3. Install the thermostatic oil cooler bypass valve with a new gasket on the oil filter base as shown in Figure 3.
- 4. Torque the thermostatic oil cooler bypass valve to 300 in.-lbs. (34 Nm).
- 5. Lockwire the thermostatic oil cooler bypass valve.




Figure 3
Oil Cooler Bypass Valve
(Engine with Oil Filter)

ISSUED			REVISED			PAGE NO.	REVISION	
MO	DAY	YEAR	MO	DAY	YEAR	2 of 2	A	S.I. 1255
08	04	72	05	13	16	2 01 2		